

Re: 41-43 Bridge Street, Berwick upon Tweed

1 message


Gordon Dickson <gordon.dickson@northumberland.gov.uk>
To: Heather Gebbie <heather.gebbie@northumberland.gov.uk>

13 March 2018 at 14:52

Heather,

I've done the above today. Mark has put in acoustic boarding into all of the openings along with acoustic wool and mastic. Where there is enough space he has also put in some concrete blocks. I've attached some photos





Gordon Dickson MRICS, B Eng (Hons)
Building Control Manager
Building Control and Land Charges Team
Business Compliance & Public Safety Unit
Fire & Rescue Service
Northumberland County Council
01670 623836
Web Address: www.northumberland.gov.uk

[LABC Building Excellence Awards](#)

On 13 March 2018 at 11:36, Heather Gebbie <heather.gebbie@northumberland.gov.uk> wrote:
Hi Gordon

Mark Dixon rang earlier (after our conversation) and suggested that you were on your way to see him.

Would it be possible to put in writing the extent of works he has had carried out on the premises and that you are satisfied with the construction standard of the separating floors and walls.

Any assistance or advice in this matter would be greatly appreciated.

Many thanks

Heather

[Heather Gebbie](#)

[Senior Licensing Officer](#)

Licensing Department

Business Compliance & Public Safety Unit

Fire & Rescue Service

Northumberland County Council

Stakeford Depot

East View

Stakeford

Choppington

NE62 5TR

[01670 623738](tel:01670623738)

